

SIMAR
2068 E MARKET ST
WAFFANEE IN 46550
574-773-0344

05/12/2023 9:05 AM

SCALD TEST REPORT

DIESEL 10205.3 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 4:27 AM
TEST STARTED 05/12/2023
STATUS 0.02
TEST ENDED 7:06 AM
TEST ENDED 05/12/2023

SLOPE -0.008 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

UNLEAD 10205.3 GAL
UNLEAD

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 2:05 AM
TEST STARTED 05/12/2023
STATUS 0.02
TEST ENDED 5:54 AM
TEST ENDED 05/12/2023

SLOPE 0.006 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREMIUM 10205.3 GAL
PREMIUM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 6:54 AM
TEST STARTED 05/12/2023
STATUS 0.02
TEST ENDED 8:57 AM
TEST ENDED 05/12/2023

SLOPE -0.036 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

K-1 4030.0 GAL
K-1

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 6:34 AM
TEST STARTED 05/12/2023
STATUS 0.02
TEST ENDED 8:35 AM
TEST ENDED 05/12/2023

SLOPE -0.013 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

SIMAR
2068 E MARKET ST
WAFFANEE IN 46550
574-773-0344

05/12/2023 9:05 AM

LEAK ESTIMATE REPORT

DIESEL

LEAK TEST 0.200 GPH
CONFIDENCE LEVEL 99.0%
GROSS CAPACITY 33.0%
GROSS 3370.3 GAL
NET 3380.0 GAL
LEVEL 95.133 IN
TEMP 53.669 F
WATER VOL 0.0 GAL
WATER LEVEL 0.000 IN
EST TIME 4 HRS 50 MIN

UNLEAD

LEAK TEST 0.200 GPH