

SIMAR
2068 E MARKET ST
WAFFANEE IN 46550
574-773-0344

07/18/2023 10:16 AM

SCALD TEST REPORT

DIESEL 10205,3 GAL
DIESEL

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 6:09 AM
TEST STARTED 07/18/2023
STATUS 0,02
TEST ENDED 8:13 AM
TEST ENDED 07/18/2023

SLOPE -0,018 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

UNLEAD 10205,3 GAL
UNLEADED

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 9:20 PM
TEST STARTED 07/18/2023
STATUS 1,02
TEST ENDED 11:26 PM
TEST ENDED 07/18/2023

SLOPE -0,069 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREMIUM 10205,3 GAL
PREMIUM

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 1:58 AM
TEST STARTED 07/18/2023
STATUS 0,02
TEST ENDED 4:31 AM
TEST ENDED 07/18/2023

SLOPE -0,098 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

K-1 4030,0 GAL
K-1

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 7:37 AM
TEST STARTED 07/18/2023
STATUS 0,02
TEST ENDED 9:38 AM
TEST ENDED 07/18/2023

SLOPE -0,026 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

SIMAR
2068 E MARKET ST
WAFFANEE IN 46550
574-773-0344

07/18/2023 10:17 AM

LEAK ESTIMATE REPORT

DIESEL

LEAK TEST 0,200 GPH
CONFIDENCE LEVEL 99,0%
GROSS CAPACITY 41,1%
GROSS 4195,1 GAL
NET 4180,2 GAL
LEVEL 41,380 IN
TEMP 67,786 F
WATER VOL 0,0 GAL
WATER LEVEL 0,000 IN
EST TIME 5 HRS 0 MIN

UNLEAD