

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
petroleumtesting@aol.com

Petroleum Testing Services, LLC tested the cathodic protection on the following tanks listed below. All results are noted below.

DATE: 3-1-2022	TIME STARTED: 1:00p
SITE ADDRESS: Simars 2068 E Market Nappanee, IN 46550	

Type of System: Galvanic

STRUCTURE TO SOIL POTENTIAL MEASUREMENT Ambient Temp 60F

DIESEL

REF CELL LOCATION	TM	VR	REMOTE
TANK CONTACT	TB at FILL	TB at FILL	TB at FILL
VOLTAGE	-622	-555	-609
RESULT	FAIL	FAIL	FAIL

UNLEAD

REF CELL LOCATION	TM	VR	REMOTE
TANK CONTACT	TB at FILL	TB at FILL	TB at FILL
VOLTAGE	-1249	-1202	-1111
RESULT	PASS	PASS	PASS

PREMIUM

REF CELL LOCATION	TM	VR	REMOTE
TANK CONTACT	TB	TB	TB
VOLTAGE	-1282	1272	-1203
RESULT	PASS	PASS	PASS

KERO

REF CELL LOCATION	TM	VR	REMOTE
TANK CONTACT	TB	TB	TB
VOLTAGE	-1357	-1345	-1301
RESULT	PASS	PASS	PASS

TESTED BY: John Lannom Certification UC20129333