

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
EMAIL:petroleumtesting@aol.com

SITE NAME: MARATHON
STREET NAME: 2068 E MARKET ST FID 18406
CITY,STATE,ZIP: NAPPANEE, IN 46550
DATE: 1/9/2023 TIME: 1:00P

LINE AND LEAK DETECTOR TEST

PRODUCT	UNL	PREM	3	4	5
OPERATING SYSTEM	PR	PR	DSL		
STP MODEL	RJ	RJ	RJ		
OPERATING PRESSURE	30	30	30		
TEST PRESSURE	50	50	50		
ISOLATION	BV	BV	BV		
LINE MATERIAL	FG	FG	FG		
BEGINNING LEVEL	0.0660	0.0425	0.0725		
10 MIN	0.0660	0.0425	0.0725		
20 MIN	0.0660	0.0425	0.0725		
30 MIN	0.0660	0.0425	0.0725		
AMOUNT OF CHANGE	0.0000	0.0000	0.0000		
RESULT	PASS	PASS	PASS		
LEAK DETECTOR MODEL	FE	FE	VMI		
LEAK DETECTOR MAKE	MLD	MLD	LD2000		
OPENING TIME	2	2	2		
PAUSE PRESSURE	16	16	22		
HOLDING PRESSURE	15	15	12		
TYPE OF TEST	3GAL/HR	3GAL/HR	3GAL/HR		
RESULT	PASS	PASS	PASS		

COMMENTS

TECHNICIAN JOHN LANNOM CERTIFICATION UC20129333