

SIMAR
2008 E MARKET ST
HAPPREE IN 40550
574-773-0340

03/29/2024 7:51 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM NOT INSTALLED
TS-ROM NOT INSTALLED
TS-SEM 1 NOT INSTALLED
TS-SEM 2 NOT INSTALLED
TS-CYP NOT INSTALLED
PRINTER OPERATIONAL
FAX/MOD OPERATIONAL

PROBES

PROBE 1 OPERATIONAL
PROBE 2 OPERATIONAL
PROBE 3 OPERATIONAL
PROBE 4 OPERATIONAL

AUXILIARY INPUTS

AUX IN 1 OPERATIONAL
AUX IN 2 OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

TANK 4

NO DATA

PASSED SLOD TESTS

TANK 1

03/29/2024 7:41 PM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH

03/15/2024 10:43 PM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH

02/14/2024 11:29 PM
LEAK TEST 0.20 GPH
SLOPE -0.02 GPH

01/15/2024 10:34 PM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH

12/16/2023 10:45 PM
LEAK TEST 0.20 GPH
SLOPE -0.01 GPH

11/16/2023 9:40 PM
LEAK TEST 0.20 GPH
SLOPE -0.02 GPH

10/17/2023 10:43 PM
LEAK TEST 0.20 GPH
SLOPE 0.04 GPH

09/17/2023 11:05 PM
LEAK TEST 0.20 GPH
SLOPE 0.07 GPH

08/18/2023 11:23 PM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH

07/19/2023 11:33 PM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH

06/19/2023 10:26 PM
LEAK TEST 0.20 GPH
SLOPE -0.00 GPH

05/20/2023 11:31 PM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH

04/20/2023 10:32 PM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH

03/21/2023 9:28 PM
LEAK TEST 0.20 GPH
SLOPE -0.03 GPH

TANK 2

03/28/2024 2:18 AM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH

03/12/2024 11:03 PM
LEAK TEST 0.20 GPH
SLOPE -0.05 GPH

02/11/2024 8:54 PM
LEAK TEST 0.20 GPH
SLOPE 0.05 GPH

01/15/2024 10:55 PM
LEAK TEST 0.20 GPH
SLOPE -0.01 GPH

12/16/2023 10:07 PM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH

11/16/2023 11:10 PM
LEAK TEST 0.20 GPH
SLOPE -0.05 GPH

10/17/2023 8:42 PM
LEAK TEST 0.20 GPH
SLOPE -0.04 GPH

06/18/2023	8:50 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
06/18/2023	10:06 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH
07/16/2023	5:20 AM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH
08/21/2023	6:08 AM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH
05/04/2023	2:52 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
04/24/2023	9:42 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
03/26/2023	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
TANK 3	
03/29/2024	5:16 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH
03/04/2024	10:32 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
03/23/2024	9:59 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
01/24/2024	11:32 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
12/25/2023	10:49 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
11/25/2023	5:07 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
10/26/2023	11:06 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
09/26/2023	10:09 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
08/27/2023	11:41 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH
07/28/2023	11:43 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
06/29/2023	3:42 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH
05/29/2023	11:42 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
04/29/2023	11:15 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
03/30/2023	8:11 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
02/26/2023	10:22 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
TANK 4	
03/29/2024	5:54 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
03/04/2024	10:04 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
02/03/2024	11:12 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
01/04/2024	8:13 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
12/14/2023	8:31 PM
LEAK TEST	0.20 GPH
SLOPE	-0.08 GPH
11/17/2023	9:55 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
10/16/2023	3:44 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
09/18/2023	10:57 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
08/19/2023	11:38 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
07/20/2023	10:21 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
06/20/2023	11:32 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
05/21/2023	11:31 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
04/21/2023	10:18 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
03/22/2023	10:07 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH