



5296 Breakers Way, Carmel, IN 46033

Date

9/13/24

PRODUCT LINE TEST

Test Location Information

Name	FID 18406
Address	2068 E Market St
City	Nappanee,IN,46550
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
11:50am	87	0	0.0037	0	0
12:05p	86	-1	0.0037	.0037	.0148
12:20p	86	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
12:35p	90	0	0.0037	0	0
12:50p	89	-1	0.0037	.0037	.0148
1:05pm	88	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
1:20pm	90	0	0.0037	0	0
1:35pm	90	0	0.0037	0	0
1:50pm	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 9/13/24

PRODUCT LINE TEST

Test Location Information

Name	FID 18406
Address	2068 E Market St
City	Nappanee, IN 46550
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Diesel	Pass
4		.
5		.
6		.

Regular line' s plug is too close to the side of the containment, had to go through the filter to test.
Kerosene line is European suction and was not tested.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 