

Oil
Tank Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	18406	Contact Number	
Facility Name	MARATHON	Contact email	
Address	2068 E Market St, Nappanee, IN 46550	Date of Inspection	11/15/24
Operator on Duty Name		Name of the Person Conducting Inspection	AKSM17

Operator Training current	☐ Yes	☐ No	Operator Training	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	Registration/Notification Form	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Release Detection Method	☒ ATG	☐ DIM	Release Detection	☐ ATG	☐ DIM	Operator Notified	☐ Yes	☐ No
Make and Model	FIS TS 750					Operator Notified	☐ Yes	☐ No
Does it have paper?	☒ Yes	☐ No				Operator Notified	☐ Yes	☐ No
Is it in Alarm mode?	☒ Yes	☐ No				Operator Notified	☐ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No				Operator Notified	☐ Yes	☐ No
Necessary Monthly Printout Taken	☒ Yes	☐ No				Operator Notified	☐ Yes	☐ No
Spill Buckets	☒ Yes	☐ No	Spill Buckets	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No				Operator Notified	☐ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No				Operator Notified	☐ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Fill Ports	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Piping/STP Sumps	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Under Dispenser Containments (UDC)	☒ Yes	☐ No				Operator Notified	☐ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No				Operator Notified	☐ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com