

LEAK RATE
2008 E MARKET ST
1021 EIGHTH 6422ED
2008 0100100148

LEAK RATE
2008 E MARKET ST
1021 EIGHTH 6422ED

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

06/14/2024 5:11 PM

LEAK TEST REPORT

DIESEL 10205.3 GAL

DIESEL

NO DATA

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

06/14/2024 5:11 PM

LEAK TEST REPORT

UNLEAD 10205.3 GAL

UNLEADED

NO DATA

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

06/14/2024 5:11 PM

LEAK TEST REPORT

PREMIUM 10205.3 GAL

PREMIUM

NO DATA

2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

06/14/2024 5:11 PM

SCALD TEST REPORT

DIESEL 10205.3 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 12:16 PM
TEST STARTED 06/14/2024
STATUS 0.02
TEST ENDED 4:24 PM
TEST ENDED 06/14/2024

SLOPE 0.012 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

06/14/2024 5:11 PM

SCALD TEST REPORT

UNLEAD 10205.3 GAL
UNLEADED

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 12:33 AM
TEST STARTED 06/14/2024
STATUS 0.02
TEST ENDED 2:39 AM
TEST ENDED 06/14/2024

SLOPE 0.008 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

06/14/2024 5:11 PM

SCALD TEST REPORT

PREMIUM 10205.3 GAL
PREMIUM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 12:31 PM
TEST STARTED 06/14/2024
STATUS 0.02
TEST ENDED 4:21 PM
TEST ENDED 06/14/2024

SLOPE 0.064 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE