

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	18986	Contact Number	
Facility Name	Maxon	Contact email	
Address	2068 E Market St, Appanet	Date of Inspection	06/14/24
Operator on Duty Name	IN 46550	Name of the Person Conducting Inspection	AKSHIT SAHARAN

Operator Training		Registration/Notification Form	
Operator Training current	☐ Yes ☐ No	Registration/Notification Form	☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Release Detection	☐ Yes ☐ No
Release Detection Method	☒ ATG ☐ BIM		☐ SIR ☐ IC ☐ Other
Make and Model	CS TS 750		
Does it have paper?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Necessary Monthly Printout Taken	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No

Spill Buckets			
Are Spill Buckets Clean and free from water, debris, product etc?	☐ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☐ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☐ No	Operator Notified	☒ Yes ☐ No

Under Dispenser Containments (UDC)			
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☐ No	Operator Notified	☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com