

oil
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 18406	Contact Number
Facility Name MAPA-TION	Contact email
Address 2068 Elm Street, Naperville, IL 60563	Date of Inspection 07/22/24
Operator on Duty Name	Name of the Person Conducting Inspection AKSHIT SHARMA

Operator Training		Registration/Notification Form	
Operator Training current	☐ Yes ☐ No	Registration/Notification Form	☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Release Detection	☐ Yes ☐ No
Release Detection Method	☒ ATG ☐ DIM ☐ SIR	Release Detection	☐ Yes ☐ No
Make and Model	FFS TS 750	Release Detection	☐ Yes ☐ No
Does it have paper?	☒ Yes ☐ No	Release Detection	☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No	Release Detection	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Release Detection	☐ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No	Release Detection	☐ Yes ☐ No

Spill Buckets		Fill Ports	
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator/Notified	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator/Notified	☒ Yes ☐ No

Piping/STP Sumps		Operator/Notified	
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator/Notified	☒ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator/Notified	☒ Yes ☐ No
Under Dispenser Containments (UDC)	☒ Yes ☐ No	Operator/Notified	☒ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator/Notified	☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com