

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

07/23/2024 3:57 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL
PROBE 4	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

TANK 4

NO DATA

PASSED SCALD TESTS

TANK 1

07/23/2024	1:50 PM
LEAK TEST	0,20 GPH
SLOPE	0,03 GPH

07/13/2024	11:34 PM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH

06/13/2024	11:09 PM
LEAK TEST	0,20 GPH
SLOPE	0,03 GPH

SLOPE 0,03 GPH

05/14/2024 9:59 PM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

04/14/2024 11:41 PM
LEAK TEST 0,20 GPH
SLOPE -0,03 GPH

03/15/2024 10:43 PM
LEAK TEST 0,20 GPH
SLOPE 0,00 GPH

02/14/2024 11:29 PM
LEAK TEST 0,20 GPH
SLOPE -0,02 GPH

01/15/2024 10:34 PM
LEAK TEST 0,20 GPH
SLOPE 0,00 GPH

12/16/2023 10:45 PM
LEAK TEST 0,20 GPH
SLOPE -0,01 GPH

11/16/2023 9:40 PM
LEAK TEST 0,20 GPH
SLOPE -0,02 GPH

10/17/2023 10:43 PM
LEAK TEST 0,20 GPH
SLOPE 0,04 GPH

09/17/2023 11:05 PM
LEAK TEST 0,20 GPH
SLOPE 0,07 GPH

08/18/2023 11:23 PM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

07/19/2023 11:33 PM
LEAK TEST 0,20 GPH
SLOPE 0,01 GPH

TANK 2

07/23/2024 3:02 AM
LEAK TEST 0,20 GPH
SLOPE -0,05 GPH

07/10/2024 10:18 PM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

06/10/2024 10:06 PM
LEAK TEST 0,20 GPH
SLOPE -0,04 GPH

05/11/2024 10:10 PM
LEAK TEST 0,20 GPH
SLOPE -0,07 GPH

04/11/2024 11:21 PM
LEAK TEST 0,20 GPH
SLOPE -0,04 GPH

03/12/2024 11:03 PM
LEAK TEST 0,20 GPH
SLOPE -0,05 GPH

02/11/2024 8:54 PM
LEAK TEST 0,20 GPH
SLOPE 0,05 GPH

01/15/2024	10:55 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

12/16/2023	10:07 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH

11/16/2023	11:10 PM
LEAK TEST	0,20 GPH
SLOPE	-0,05 GPH

10/17/2023	8:42 PM
LEAK TEST	0,20 GPH
SLOPE	-0,04 GPH

09/17/2023	8:59 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

08/18/2023	10:26 PM
LEAK TEST	0,20 GPH
SLOPE	-0,05 GPH

07/19/2023	5:20 AM
LEAK TEST	0,20 GPH
SLOPE	-0,06 GPH

TANK 3

07/23/2024	11:52 AM
LEAK TEST	0,20 GPH
SLOPE	0,04 GPH

07/22/2024	11:15 PM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH

06/22/2024	9:14 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH

05/23/2024	11:46 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH

04/23/2024	11:42 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

03/24/2024	10:32 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH

02/23/2024	9:59 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

01/24/2024	11:32 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

12/25/2023	10:49 PM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH

11/25/2023	5:07 AM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH

10/26/2023	11:06 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH

09/26/2023	10:09 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH

08/27/2023	11:41 PM
LEAK TEST	0,20 GPH
SLOPE	0,04 GPH

07/28/2023	11:43 PM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH

06/28/2023	3:42 PM
LEAK TEST	0,20 GPH
SLOPE	-0,05 GPH

TANK 4

07/23/2024	3:24 PM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH

07/01/2024	4:15 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH

06/02/2024	6:22 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH

05/03/2024	10:04 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

04/03/2024	11:11 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

03/04/2024	10:04 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH

02/03/2024	11:12 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

01/04/2024	8:13 AM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH

12/14/2023	8:31 PM
LEAK TEST	0,20 GPH
SLOPE	-0,08 GPH

11/17/2023	9:55 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH

10/18/2023	3:44 PM
LEAK TEST	0,20 GPH
SLOPE	-0,03 GPH

09/18/2023	10:57 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH

08/19/2023	11:38 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH

07/20/2023	10:21 PM
LEAK TEST	0,20 GPH
SLOPE	-0,02 GPH