

SIMAR
2068 E MARKET ST
WAIPANEE IN 46550
574-773-0344

10/23/2024 3:19 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CFM	NOT INSTALLED
PRINTER	OPERATIONAL
FAK/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL
PROBE 4	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

TANK 4

NO DATA

PASSED SCALD TESTS

TANK 1

10/23/2024	12:34 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

10/11/2024	10:55 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

09/11/2024	11:23 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

08/12/2024	2:13 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

07/13/2024	11:34 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

06/13/2024	11:09 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

05/14/2024	9:59 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

04/14/2024	11:41 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

03/15/2024	10:43 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

02/14/2024	11:29 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

01/15/2024	10:34 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

12/16/2023	10:45 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

11/16/2023	9:40 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

10/17/2023	10:43 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

TANK 2

10/23/2024	2:59 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

10/08/2024	10:44 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH

09/08/2024	7:23 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

08/09/2024	11:54 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

07/10/2024	10:18 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

06/10/2024	10:06 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

05/11/2024	10:10 PM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH

04/11/2024	11:21 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

03/12/2024	11:03 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH

02/11/2024	8:54 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH

01/15/2024	10:55 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

12/16/2023	10:07 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

11/16/2023	11:10 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH

10/17/2023	8:42 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

TANK 3

10/23/2024	2:05 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

10/20/2024	10:46 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

09/20/2024	10:03 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH

08/21/2024	11:25 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

07/22/2024	11:15 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

06/22/2024	9:14 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

05/23/2024	11:46 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
04/23/2024	11:42 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
03/24/2024	10:32 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
02/23/2024	9:59 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
01/24/2024	11:32 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
12/25/2023	10:49 PM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH
11/25/2023	5:07 AM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH
10/26/2023	11:06 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
09/26/2023	10:09 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH
TANK 4	
10/23/2024	2:11 PM
LEAK TEST	0,20 GPH
SLOPE	-0,03 GPH
09/29/2024	9:44 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH
08/30/2024	10:57 PM
LEAK TEST	0,20 GPH
SLOPE	0,04 GPH
07/31/2024	6:52 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
07/01/2024	4:15 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
06/02/2024	6:22 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH
05/03/2024	10:04 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
04/03/2024	11:11 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
03/04/2024	10:04 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH
02/03/2024	11:12 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
01/04/2024	8:13 AM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH
12/14/2023	8:31 PM
LEAK TEST	0,20 GPH
SLOPE	-0,08 GPH
11/17/2023	9:55 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH
10/18/2023	3:44 PM
LEAK TEST	0,20 GPH
SLOPE	-0,03 GPH