

SIMAR
NAPPANEE
2068 E MARKET ST
NAPPANEE IN 46550
1-574-773-0344

10/30/2025

1:54 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL
PROBE 4	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

TANK 4

NO DATA

PASSED SCALD TESTS

TANK 1

10/30/2025	12:19 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

09/30/2025	10:19 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

08/31/2025	10:29 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

08/01/2025	11:19 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

11/29/2007	6:00 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

TANK 2

10/29/2025	4:12 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

10/13/2025	11:41 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

09/13/2025	5:01 AM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

08/14/2025	12:50 AM
LEAK TEST	0.20 GPH
SLOPE	0.09 GPH

TANK 3

10/30/2025	11:13 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

10/11/2025	11:24 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

09/11/2025	11:32 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

08/12/2025	4:36 PM
LEAK TEST	0.20 GPH
SLOPE	0.08 GPH

TANK 4

10/30/2025	11:47 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

10/25/2025	8:16 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

09/25/2025	11:26 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

SIMAR
NAPPANEE
2068 E MARKET ST
NAPPANEE IN 46550
1-574-773-0344

10/30/2025	1:55 PM
------------	---------

LEAK TEST REPORT

DIESEL	10152.3 GAL
--------	-------------

PROD 1

NO DATA

UNLEAD	10152.3 GAL
--------	-------------

PROD 2

NO DATA

PREMIUM	10152.3 GAL
---------	-------------

PROD 3

NO DATA

K-1	547.9 GAL
-----	-----------

PROD 4

NO DATA