

SIMAR
2068 E MARKET ST
NAPPANEE IN 48550
574-773-0344

01/19/2025 4:25 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL
PROBE 4	TROUBLE

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

TANK 4

NO DATA

PASSED SCALD TESTS

TANK 1

01/19/2025	3:03 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
01/09/2025	3:25 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH
12/10/2024	10:00 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH
11/10/2024	10:41 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
10/11/2024	10:55 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH
09/11/2024	11:23 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
08/12/2024	2:13 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
07/13/2024	11:34 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
06/13/2024	11:09 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
05/14/2024	9:59 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
04/14/2024	11:41 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
03/15/2024	10:43 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
02/14/2024	11:29 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
01/15/2024	10:34 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

TANK 2

01/13/2025	2:17 AM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH
01/04/2025	7:53 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
12/06/2024	1:11 AM
LEAK TEST	0.20 GPH
SLOPE	-0.08 GPH
11/06/2024	4:08 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
10/08/2024	10:44 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH
09/08/2024	7:23 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
08/09/2024	11:54 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

07/10/2024	10:18 PM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH
06/10/2024	10:06 PM
LEAK TEST	0,20 GPH
SLOPE	-0,04 GPH
05/11/2024	10:10 PM
LEAK TEST	0,20 GPH
SLOPE	-0,07 GPH
04/11/2024	11:21 PM
LEAK TEST	0,20 GPH
SLOPE	-0,04 GPH
03/12/2024	11:03 PM
LEAK TEST	0,20 GPH
SLOPE	-0,05 GPH
02/11/2024	8:54 PM
LEAK TEST	0,20 GPH
SLOPE	0,05 GPH
01/15/2024	10:55 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

TANK 3

01/19/2025	1:51 PM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH
01/18/2025	6:55 AM
LEAK TEST	0,20 GPH
SLOPE	0,07 GPH
12/19/2024	9:43 PM
LEAK TEST	0,20 GPH
SLOPE	-0,06 GPH
11/19/2024	10:24 PM
LEAK TEST	0,20 GPH
SLOPE	-0,04 GPH
10/20/2024	10:46 PM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH
09/20/2024	10:03 PM
LEAK TEST	0,20 GPH
SLOPE	-0,05 GPH
08/21/2024	11:25 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
07/22/2024	11:15 PM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH
06/22/2024	9:14 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
05/23/2024	11:46 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
04/23/2024	11:42 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
03/24/2024	10:32 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
02/23/2024	9:59 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
01/24/2024	11:32 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
12/25/2023	10:49 PM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH

TANK 4

11/29/2024	7:04 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
11/28/2024	11:27 PM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH
10/29/2024	11:38 PM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH
09/29/2024	9:44 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH
08/30/2024	10:57 PM
LEAK TEST	0,20 GPH
SLOPE	0,04 GPH
07/31/2024	6:52 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
07/01/2024	4:15 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH
06/02/2024	6:22 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH
05/03/2024	10:04 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
04/03/2024	11:11 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
03/04/2024	10:04 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH
02/03/2024	11:12 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH
01/04/2024	8:13 AM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH