

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

03/26/2025 6:42 AM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL
PROBE 4	TROUBLE

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

TANK 4

NO DATA

PASSED SCALD TESTS

TANK 1

03/26/2025	4:35 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

03/10/2025	10:20 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

02/08/2025	10:11 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

01/09/2025	3:25 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

12/10/2024	10:00 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

11/10/2024	10:41 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

10/11/2024	10:55 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

09/11/2024	11:23 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

08/12/2024	2:13 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

07/13/2024	11:34 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

06/13/2024	11:09 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

05/14/2024	9:59 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

04/14/2024	11:41 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

03/15/2024	10:43 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

TANK 2

03/26/2025	12:06 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

03/03/2025	2:05 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH