

# Tanks Data

## 30 DAYS WALK THROUGH INSPECTION

|                                           |                                                  |
|-------------------------------------------|--------------------------------------------------|
| UST Facility I.D. (FID) # 18706           | Contact Number                                   |
| Facility Name Maxethon                    | Contact email                                    |
| Address 2068 E Maxwell St                 | Date of Inspection 03/26/25                      |
| Operator on Duty Name Nalpaner In - 46550 | Name of the Person Conducting Inspection Ashli T |

  

|                                                                   |                                      |                                     |                   |                           |                             |
|-------------------------------------------------------------------|--------------------------------------|-------------------------------------|-------------------|---------------------------|-----------------------------|
| Operator Training current                                         | <input type="radio"/> Yes            | <input type="radio"/> No            | Operator Notified | <input type="radio"/> Yes | <input type="radio"/> No    |
| Is Registration current with correct owner, operator etc.         | Registration/Notification Form       |                                     | Operator Notified | <input type="radio"/> Yes | <input type="radio"/> No    |
| Release Detection Method                                          | Release Detection                    |                                     | Operator Notified | <input type="radio"/> Yes | <input type="radio"/> No    |
| Make and Model Incon TS - 750                                     | <input checked="" type="radio"/> ATG | <input type="radio"/> CIM           | Operator Notified | <input type="radio"/> IC  | <input type="radio"/> Other |
| Does it have paper?                                               | <input checked="" type="radio"/> Yes | <input type="radio"/> No            | Operator Notified | <input type="radio"/> Yes | <input type="radio"/> No    |
| Is it in Alarm mode?                                              | <input type="radio"/> Yes            | <input checked="" type="radio"/> No | Operator Notified | <input type="radio"/> Yes | <input type="radio"/> No    |
| Interstitial Monitoring Sensor Status Normal                      | <input type="radio"/> Yes            | <input checked="" type="radio"/> No | Operator Notified | <input type="radio"/> Yes | <input type="radio"/> No    |
| Necessary Monthly Printout Taken                                  | <input type="radio"/> Yes            | <input checked="" type="radio"/> No | Operator Notified | <input type="radio"/> Yes | <input type="radio"/> No    |
| Are Spill Buckets Clean and free from water, debris, product etc? | Spill Buckets                        |                                     | Operator Notified | <input type="radio"/> Yes | <input type="radio"/> No    |
| Are the Spill Bucket in good condition and free of damage/cracks  | <input checked="" type="radio"/> Yes | <input type="radio"/> No            | Operator Notified | <input type="radio"/> Yes | <input type="radio"/> No    |
| Is Fill pipe cap tight and fill pipe free from any obstruction?   | Fill Ports                           |                                     | Operator Notified | <input type="radio"/> Yes | <input type="radio"/> No    |
| Are Sumps Clean and free from water, debris, product etc?         | Piping/STP Sumps                     |                                     | Operator Notified | <input type="radio"/> Yes | <input type="radio"/> No    |
| Are UDCs clean and free from water, debris, product etc?          | Under Dispenser Containments (UDC)   |                                     | Operator Notified | <input type="radio"/> Yes | <input type="radio"/> No    |

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

Signature

Date

tanksdata@gmail.com

www.tanksdata.com