

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

04/08/2025 4:18 PM

SCALD TEST REPORT

DIESEL 10205.3 GAL

DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 6:57 AM
TEST STARTED 04/08/2025
STATUS 0.02
TEST ENDED 11:33 AM
TEST ENDED 04/08/2025

SLOPE 0.006 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

04/08/2025 4:18 PM

SCALD TEST REPORT

UNLEAD 10205.3 GAL

UNLEADED

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 1:20 AM
TEST STARTED 04/08/2025
STATUS 0.02
TEST ENDED 5:26 AM
TEST ENDED 04/08/2025

SLOPE 0.004 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

04/08/2025 4:18 PM

SCALD TEST REPORT

PREMIUM 10205.3 GAL

PREMIUM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 12:45 AM
TEST STARTED 04/02/2025
STATUS 0.02
TEST ENDED 2:49 AM
TEST ENDED 04/02/2025

SLOPE 0.045 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

04/08/2025 4:18 PM

SCALD TEST REPORT

K-1 4030.0 GAL

K-1

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 4:05 PM
TEST STARTED 11/29/2024
STATUS 0.02
TEST ENDED 7:04 PM
TEST ENDED 11/29/2024

SLOPE 0.011 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

04/08/2025 4:18 PM

TANK INVENTORY SUMMARY

(GROSS VOLUME)

DIESEL	1059.6 GAL
UNLEAD	5850.8 GAL
PREMIUM	FLT MISSING
K-1	FLT MISSING

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

04/08/2025 4:18 PM

LEAK TEST REPORT

DIESEL	10205.3 GAL
--------	-------------

DIESEL

NO DATA

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

04/08/2025 4:18 PM

LEAK TEST REPORT

UNLEAD	10205.3 GAL
--------	-------------

UNLEADED

NO DATA

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

04/08/2025 4:18 PM

LEAK TEST REPORT

PREMIUM	10205.3 GAL
---------	-------------

PREMIUM

NO DATA

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

04/08/2025 4:19 PM

LEAK TEST REPORT

K-1	4030.0 GAL
-----	------------

K-1

NO DATA