

SIMAR  
2068 E MARKET ST  
NAPPANEE IN 46550  
574-773-0344

02/14/2025

4:27 PM

# REGULATORY REPORT

## HARDWARE STATUS

|          |               |
|----------|---------------|
| TS-CIM   | NOT INSTALLED |
| TS-ROM   | NOT INSTALLED |
| TS-SEM 1 | NOT INSTALLED |
| TS-SEM 2 | NOT INSTALLED |
| TS-CPM   | NOT INSTALLED |
| PRINTER  | OPERATIONAL   |
| FAX/MOD  | OPERATIONAL   |

## PROBES

|         |             |
|---------|-------------|
| PROBE 1 | OPERATIONAL |
| PROBE 2 | OPERATIONAL |
| PROBE 3 | OPERATIONAL |
| PROBE 4 | TROUBLE     |

## AUXILIARY INPUTS

|          |             |
|----------|-------------|
| AUX IN 1 | OPERATIONAL |
| AUX IN 2 | OPERATIONAL |

## PASSED LEAK TESTS

### TANK 1

NO DATA

### TANK 2

NO DATA

### TANK 3

NO DATA

### TANK 4

NO DATA

## PASSED SCALD TESTS

### TANK 1

|            |           |
|------------|-----------|
| 02/14/2025 | 4:25 PM   |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | 0.02 GPH  |
| 02/08/2025 | 10:11 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.02 GPH |
| 01/09/2025 | 3:25 PM   |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | 0.04 GPH  |
| 12/10/2024 | 10:00 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | 0.04 GPH  |
| 11/10/2024 | 10:41 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | 0.03 GPH  |
| 10/11/2024 | 10:55 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | 0.04 GPH  |
| 09/11/2024 | 11:23 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | 0.02 GPH  |
| 08/12/2024 | 2:13 PM   |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | 0.00 GPH  |
| 07/13/2024 | 11:34 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.00 GPH |
| 06/13/2024 | 11:09 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | 0.03 GPH  |
| 05/14/2024 | 9:59 PM   |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | 0.02 GPH  |
| 04/14/2024 | 11:41 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.03 GPH |
| 03/15/2024 | 10:43 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | 0.00 GPH  |
| 02/14/2024 | 11:29 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.02 GPH |

### TANK 2

|            |           |
|------------|-----------|
| 02/11/2025 | 5:02 AM   |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | 0.04 GPH  |
| 02/01/2025 | 4:51 AM   |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | 0.08 GPH  |
| 01/04/2025 | 7:53 AM   |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.04 GPH |

|            |           |
|------------|-----------|
| 12/06/2024 | 1:11 AM   |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.08 GPH |

|            |           |
|------------|-----------|
| 11/06/2024 | 4:08 AM   |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.01 GPH |

|            |          |
|------------|----------|
| 10/08/2024 | 10:44 PM |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.05 GPH |

|            |           |
|------------|-----------|
| 09/08/2024 | 7:23 AM   |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.02 GPH |

|            |           |
|------------|-----------|
| 08/09/2024 | 11:54 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.03 GPH |

|            |          |
|------------|----------|
| 07/10/2024 | 10:18 PM |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.02 GPH |

|            |           |
|------------|-----------|
| 06/10/2024 | 10:06 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.04 GPH |

|            |           |
|------------|-----------|
| 05/11/2024 | 10:10 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.07 GPH |

|            |           |
|------------|-----------|
| 04/11/2024 | 11:21 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.04 GPH |

|            |           |
|------------|-----------|
| 03/12/2024 | 11:03 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.05 GPH |

|            |          |
|------------|----------|
| 02/11/2024 | 8:54 PM  |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.05 GPH |

TANK 3

|            |          |
|------------|----------|
| 02/14/2025 | 3:46 PM  |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.02 GPH |

|            |          |
|------------|----------|
| 01/18/2025 | 6:55 AM  |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.07 GPH |

|            |           |
|------------|-----------|
| 12/19/2024 | 9:43 PM   |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.06 GPH |

|            |           |
|------------|-----------|
| 11/19/2024 | 10:24 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.04 GPH |

|            |          |
|------------|----------|
| 10/20/2024 | 10:46 PM |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.02 GPH |

|            |           |
|------------|-----------|
| 09/20/2024 | 10:03 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.05 GPH |

|            |          |
|------------|----------|
| 08/21/2024 | 11:25 PM |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.01 GPH |

|            |           |
|------------|-----------|
| 07/22/2024 | 11:15 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.00 GPH |

|            |          |
|------------|----------|
| 06/22/2024 | 9:14 PM  |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.01 GPH |

|            |          |
|------------|----------|
| 05/23/2024 | 11:46 PM |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.01 GPH |

|            |           |
|------------|-----------|
| 04/23/2024 | 11:42 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.01 GPH |

|            |          |
|------------|----------|
| 03/24/2024 | 10:32 PM |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.01 GPH |

|            |           |
|------------|-----------|
| 02/23/2024 | 9:59 PM   |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.01 GPH |

|            |           |
|------------|-----------|
| 01/24/2024 | 11:32 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.01 GPH |

TANK 4

|            |          |
|------------|----------|
| 11/29/2024 | 7:04 PM  |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.01 GPH |

|            |          |
|------------|----------|
| 11/28/2024 | 11:27 PM |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.02 GPH |

|            |           |
|------------|-----------|
| 10/29/2024 | 11:38 PM  |
| LEAK TEST  | 0.20 GPH  |
| SLOPE      | -0.00 GPH |

|            |          |
|------------|----------|
| 09/29/2024 | 9:44 PM  |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.00 GPH |

|            |          |
|------------|----------|
| 08/30/2024 | 10:57 PM |
| LEAK TEST  | 0.20 GPH |
| SLOPE      | 0.04 GPH |

|            |         |
|------------|---------|
| 07/31/2024 | 6:52 PM |
|------------|---------|