

SIMAR
NAPPANEE
2068 E MARKET ST
NAPPANEE IN 46550
1-574-773-0344

08/28/2025

6:25 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	NOT INSTALLED
FAX/MOD	OPERATIONAL
	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
---------	-------------

SENSORS

SENSOR 1	OPERATIONAL
SENSOR 2	OPERATIONAL
SENSOR 3	OPERATIONAL
SENSOR 4	OPERATIONAL
SENSOR 5	OPERATIONAL
SENSOR 6	OPERATIONAL
SENSOR 7	OPERATIONAL
SENSOR 8	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

PASSED SCALD TESTS

TANK 1

08/28/2025	3:26 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
08/01/2025	11:19 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
11/29/2007	6:00 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

SIMAR
NAPPANEE
2068 E MARKET ST
NAPPANEE IN 46550
1-574-773-0344

08/28/2025 6:25 PM

SENSOR STATUS REPORT

SENSOR NO. 1

SENSOR 1

OK

SENSOR NO. 2

SENSOR 2

OK

SENSOR NO. 3

SENSOR 3

OK

SENSOR NO. 4

SENSOR 4

OK

SENSOR NO. 5

SENSOR 5

OK

SENSOR NO. 6

SENSOR 6

OK

SENSOR NO. 7

SENSOR 7

OK

SENSOR NO. 8

SENSOR 8

OK