


ATG Not Printing

Tanks Data		30 DAYS WALK THROUGH INSPECTION	
UST Facility I.D. (FID) #	18406	Contact Number	
Facility Name	Murphy	Contact email	
Address	2068 E Market St 46550	Date of Inspection	07-31-2025
Operator on Duty Name		Name of the Person Conducting Inspection	burpelt
Operator Training Operator Training current ☐ Yes ☐ No Registration/Notification Form Is Registration current with correct owner, operator etc. ☐ Yes ☐ No Release Detection Release Detection Method ☐ ATG ☐ CIM ☐ SIR ☐ IC ☐ Other Make and Model Does it have paper? ☐ Yes ☐ No Is it in Alarm mode? ☐ Yes ☐ No Interstitial Monitoring Sensor Status Normal ☐ Yes ☐ No Necessary Monthly Printout Taken ☐ Yes ☐ No Spill Buckets Are Spill Buckets Clean and free from water, debris, product etc? ☐ Yes ☒ No Are the Spill Bucket in good condition and free of damage/cracks ☒ Yes ☐ No Fill Ports Is Fill pipe cap tight and fill pipe free from any obstruction? ☐ Yes ☐ No Piping/STP Sumps Are Sumps Clean and free from water, debris, product etc? ☐ Yes ☒ No Under Dispenser Containments (UDC) Are UDCs clean and free from water, debris, product etc? ☐ Yes ☒ No			
Operator Notified Operator Notified ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No Operator Notified ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No Operator Notified ☒ Yes ☐ No Operator Notified ☐ Yes ☐ No Operator Notified ☒ Yes ☐ No			
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.			
Operator on Duty Name		Signature	
317-645-0215			
tanksdata@gmail.com		Date 07-31-2025	
		www.tanksdata.com	
20220516			