



5296 Breakers Way, Carmel, IN 46033

Date 9/26/25

## PRODUCT LINE TEST

### Test Location Information

|         |                     |
|---------|---------------------|
| Name    | FID 18406           |
| Address | 2068 E Market St    |
| City    | Nappanee, IN, 46550 |
| Phone   |                     |
| Contact |                     |

### Technician Information

|        |             |
|--------|-------------|
| Name   | Josh Rider  |
| Cert # | UC202406986 |

### Applied Pressure

|        |
|--------|
| 50 psi |
|--------|

### #1 Product Type : Regular

| TIME                | DATA | +/- | GPL    | RES   | GPH   |
|---------------------|------|-----|--------|-------|-------|
| 12:40p              | 83   | 0   | 0.0037 | 0     | 0     |
| 12:55p              | 83   | -1  | 0.0037 | .0037 | .0148 |
| 1:10pm              | 83   | -1  | 0.0037 | .0037 | .0148 |
|                     |      |     | 0.0037 |       |       |
|                     |      |     | 0.0037 |       |       |
|                     |      |     | 0.0037 |       |       |
|                     |      |     | 0.0037 |       |       |
| Final Result : Pass |      |     |        |       |       |

### #2 Product Type : Premium

| TIME                | DATA | +/- | GPL    | RES   | GPH   |
|---------------------|------|-----|--------|-------|-------|
| 1:20pm              | 90   | 0   | 0.0037 | 0     | 0     |
| 1:35pm              | 89   | -1  | 0.0037 | .0037 | .0148 |
| 1:50pm              | 88   | -1  | 0.0037 | .0037 | .0148 |
|                     |      |     | 0.0037 |       |       |
|                     |      |     | 0.0037 |       |       |
|                     |      |     | 0.0037 |       |       |
|                     |      |     | 0.0037 |       |       |
| Final Result : Pass |      |     |        |       |       |

### #3 Product Type : Diesel

| TIME                | DATA | +/- | GPL    | RES | GPH |
|---------------------|------|-----|--------|-----|-----|
| 2:05pm              | 90   | 0   | 0.0037 | 0   | 0   |
| 2:20pm              | 90   | 0   | 0.0037 | 0   | 0   |
| 2:35pm              | 90   | 0   | 0.0037 | 0   | 0   |
|                     |      |     | 0.0037 |     |     |
|                     |      |     | 0.0037 |     |     |
|                     |      |     | 0.0037 |     |     |
|                     |      |     | 0.0037 |     |     |
| Final Result : Pass |      |     |        |     |     |

### #4 Product Type :

| TIME             | DATA | +/- | GPL    | RES | GPH |
|------------------|------|-----|--------|-----|-----|
|                  |      |     | 0.0037 |     |     |
|                  |      |     | 0.0037 |     |     |
|                  |      |     | 0.0037 |     |     |
|                  |      |     | 0.0037 |     |     |
|                  |      |     | 0.0037 |     |     |
|                  |      |     | 0.0037 |     |     |
|                  |      |     | 0.0037 |     |     |
| Final Result : . |      |     |        |     |     |



5296 Breakers Way, Carmel, IN 46033

Date 9/26/25

## PRODUCT LINE TEST

### Test Location Information

|         |                     |
|---------|---------------------|
| Name    | FID 18406           |
| Address | 2068 E Market St    |
| City    | Nappanee, IN, 46550 |
| Phone   |                     |
| Contact |                     |

### Technician Information

|        |             |
|--------|-------------|
| Name   | Josh Rider  |
| Cert # | UC202406986 |

### Applied Pressure

|        |
|--------|
| 50 psi |
|--------|

## FINAL REPORT

| SR. No. | Product Type | Result |
|---------|--------------|--------|
| 1       | Regular      | Pass   |
| 2       | Premium      | Pass   |
| 3       | Diesel       | Pass   |
| 4       |              |        |
| 5       |              |        |
| 6       |              |        |

Regular line' s plug is too close to the side of the containment, tested through filter.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 