Simon
2068 E MARKET ST
NAPPANEE, IN 46550
574-773-0344

06/30/2025 5:15 PM

REGULATORY REPORT

HARDWARE STATUS

S-CIM	NOT INSTALLED
S-ROM	NOT INSTALLED
S-SEM 1	NOT INSTALLED
S-SEM 2	NOT INSTALLED
S-CPM	NOT INSTALLED
INTER	NOT INSTALLED
M/MOD	OPERATIONAL
	OPERATIONAL

PROBES

OBE 1	
OBE 2	OPERATIONAL
OBE 3	OPERATIONAL
OBE 4	OPERATIONAL
	TROUBLE

AUXILIARY INPUTS

IX IN 1	
IX IN 2	OPERATIONAL
	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

TANK 4

NO DATA

PASSED SCALD TESTS

TANK 1

06/29/2025	2:37 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
06/08/2025	10:55 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
05/09/2025	11:24 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
04/09/2025	11:58 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
03/10/2025	10:20 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
02/08/2025	10:11 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
01/09/2025	3:25 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH
12/10/2024	10:00 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH
11/10/2024	10:41 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
10/11/2024	10:55 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH
09/11/2024	11:23 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
08/12/2024	2:13 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
07/13/2024	11:34 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
06/13/2024	11:09 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

TANK 2

06/18/2025	11:27 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
06/01/2025	9:38 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH
05/02/2025	10:37 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
04/02/2025	10:05 PM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH
03/03/2025	2:05 AM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH
02/01/2025	4:51 AM
LEAK TEST	0.20 GPH
SLOPE	0.08 GPH
01/04/2025	7:53 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
12/06/2024	1:11 AM
LEAK TEST	0.20 GPH
SLOPE	-0.08 GPH
11/06/2024	4:08 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

01/09/2025	3:25 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.04 GPH	
12/10/2024	10:00 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.04 GPH	
11/10/2023	10:41 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.03 GPH	
10/11/2024	10:55 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.04 GPH	
09/11/2024	11:23 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.00 GPH	
08/12/2024	2:15 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.00 GPH	
07/13/2024	11:34 PM	
LEAK TEST	0.20 GPH	
SLOPE	-0.00 GPH	
06/13/2024	11:09 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.03 GPH	

TANK 2

06/18/2025	11:27 PM	
LEAK TEST	0.20 GPH	
SLOPE	-0.01 GPH	
06/01/2025	9:38 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.05 GPH	
05/02/2025	10:37 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.03 GPH	
04/02/2025	10:05 PM	
LEAK TEST	0.20 GPH	
SLOPE	-0.09 GPH	
03/03/2025	2:05 AM	
LEAK TEST	0.20 GPH	
SLOPE	-0.09 GPH	
02/01/2025	4:51 AM	
LEAK TEST	0.20 GPH	
SLOPE	0.08 GPH	
01/04/2025	7:53 AM	
LEAK TEST	0.20 GPH	
SLOPE	-0.04 GPH	
12/06/2024	1:14 AM	
LEAK TEST	0.20 GPH	
SLOPE	-0.08 GPH	
11/06/2024	4:08 AM	
LEAK TEST	0.20 GPH	
SLOPE	-0.01 GPH	
10/08/2024	10:44 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.05 GPH	
09/08/2024	7:23 AM	
LEAK TEST	0.20 GPH	
SLOPE	-0.02 GPH	
08/08/2024	11:54 PM	
LEAK TEST	0.20 GPH	
SLOPE	-0.03 GPH	
07/10/2024	10:18 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.02 GPH	
06/10/2024	10:06 PM	
LEAK TEST	0.20 GPH	
SLOPE	-0.04 GPH	

TANK 3

06/30/2025	3:10 PM	
LEAK TEST	0.20 GPH	
SLOPE	-0.06 GPH	
06/17/2025	11:39 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.01 GPH	
05/18/2025	9:55 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.01 GPH	
04/18/2025	10:25 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.01 GPH	
03/19/2025	10:01 PM	
LEAK TEST	0.20 GPH	
SLOPE	-0.02 GPH	
02/17/2025	11:51 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.03 GPH	
01/18/2025	6:55 AM	
LEAK TEST	0.20 GPH	
SLOPE	0.07 GPH	
12/19/2024	9:43 PM	
LEAK TEST	0.20 GPH	
SLOPE	-0.06 GPH	
11/19/2024	10:24 PM	
LEAK TEST	0.20 GPH	
SLOPE	-0.04 GPH	
10/20/2024	10:48 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.02 GPH	
09/20/2024	10:03 PM	
LEAK TEST	0.20 GPH	
SLOPE	-0.05 GPH	
08/21/2024	11:25 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.01 GPH	
07/22/2024	11:15 PM	
LEAK TEST	0.20 GPH	
SLOPE	-0.00 GPH	
06/22/2024	9:14 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.01 GPH	

TANK 4

11/29/2024	7:04 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.01 GPH	
11/28/2024	11:27 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.02 GPH	
10/29/2024	11:38 PM	
LEAK TEST	0.20 GPH	
SLOPE	-0.00 GPH	
09/29/2024	9:46 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.00 GPH	
08/30/2024	10:57 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.04 GPH	
07/31/2024	8:52 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.01 GPH	
07/01/2024	8:15 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.01 GPH	
06/02/2024	8:22 PM	
LEAK TEST	0.20 GPH	
SLOPE	0.00 GPH	