

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

05/28/2025 12:55 PM

LEAK TEST REPORT

DIESEL 10205.3 GAL

DIESEL

NO DATA

UNLEAD 10205.3 GAL

UNLEADED

NO DATA

PREMIUM 10205.3 GAL

PREMIUM

NO DATA

K-1 4030.0 GAL

K-1

NO DATA

SIMAR
2068 E MARKET ST
NAPPANEE IN 46550
574-773-0344

05/28/2025 12:56 PM

SCALD TEST REPORT

DIESEL 10205.3 GAL

DIESEL

LEAK TEST 0.200 GPH

LEAK THRESHOLD 0.100 GPH

INTERVAL 18.0

VOL QUALIFY 0.0%

TEST STARTED 6:28 AM

TEST STARTED 05/28/2025

STATUS 0.02

TEST ENDED 10:04 AM

TEST ENDED 05/28/2025

SLOPE 0.005 GAL/HR

TEST RESULT PASSED

SLOPE EQUALS CALCULATED

LEAK RATE

UNLEAD 10205.3 GAL

UNLEADED

LEAK TEST 0.200 GPH

LEAK THRESHOLD 0.100 GPH

INTERVAL 18.0

VOL QUALIFY 0.0%

TEST STARTED 12:48 AM

TEST STARTED 05/28/2025

STATUS 0.02

TEST ENDED 2:56 AM

TEST ENDED 05/28/2025

SLOPE 0.035 GAL/HR

TEST RESULT PASSED

SLOPE EQUALS CALCULATED

LEAK RATE

PREMIUM 10205.3 GAL

PREMIUM

LEAK TEST 0.200 GPH

LEAK THRESHOLD 0.100 GPH

INTERVAL 18.0

VOL QUALIFY 0.0%

TEST STARTED 10:34 AM

TEST STARTED 05/28/2025

STATUS 0.02

TEST ENDED 12:08 PM

TEST ENDED 05/28/2025

SLOPE 0.020 GAL/HR

TEST RESULT PASSED

SLOPE EQUALS CALCULATED

LEAK RATE

K-1 4030.0 GAL

K-1

LEAK TEST 0.200 GPH

LEAK THRESHOLD 0.100 GPH

INTERVAL 18.0

VOL QUALIFY 0.0%

TEST STARTED 4:05 PM

TEST STARTED 11/29/2024

STATUS 0.02

TEST ENDED 7:04 PM

TEST ENDED 11/29/2024

SLOPE 0.011 GAL/HR

TEST RESULT PASSED

SLOPE EQUALS CALCULATED

LEAK RATE