

TECHNICIAN: ROGER WILLOUGHBY
PERMIT: UC202308724

T/W Maint.
~~TWPSERVICES, LLC~~
401 E 7th St
Michigan City, IN 46360
219-561-1601 / rwilloughby@twpservices.com

SITE NAME: Conoco
STREET NAME: 104 E. Lincolnway
CITY, STATE, ZIP: LAPORE IN 46350
DATE: TIME:

OVERFILL TEST

PRODUCT	RNL		PRM	
TYPE OF OVERFILL	OPW 7150		OPW 7150	
TANK SIZE	10,050		10,050	
TANK DIAMETER	96"		96	
MECHANISM MOVES FREELY?	Yes -		Yes -	
RISER LENGTH	53		47	
TOP OF RISER TO OVERFILL	63		63	
OVERFILL FROM TANK BOTTOM	86		86	
OVERFILL SET @90%				
RESULT	PASS		PASS	

NOTE 96 inch tank Highland Steel tank 10026
147 inches total -
Drop tube CUT TO 142
PRM - 143 long
Riser 47
Flapper 63
CUT TO - 139