

TECHNICIAN: ROGER WILLOUGHBY
PERMIT: UC202308724

T/W Maint.
TWPSERVICES, LLC
401 E 7th St
Michigan City, IN 46360
219-561-1601 / rwilloughby@twpservices.com

SITE NAME: Conoco
STREET NAME: 104 E. Lincolnway
CITY, STATE, ZIP: LA PORTE IN 46350
DATE: TIME:

OVERFILL TEST

PRODUCT	RNL		
TYPE OF OVERFILL	OPW 7150		
TANK SIZE	10,050		
TANK DIAMETER	96" ⁰		
MECHANISIM MOVES FREELY?	Yes -		
RISER LENGTH	53		
TOP OF RISER TO OVERFILL	63		
OVERFILL FROM TANK BOTTOM	86		
OVERFILL SET @90%			
RESULT	PASS		

CONOCO
104 E LINCONWAY
LA PORTE IN 46360

OCT 27, 2023 10:16 AM

SYSTEM STATUS REPORT

T 1:ANN TST NEEDED ALM

T 2:ANN TST NEEDED ALM

INVENTORY REPORT

T 1:RNL
VOLUME = 6117 GALS
ULLAGE = 3933 GALS
90% ULLAGE = 2928 GALS
TC VOLUME = 6101 GALS
HEIGHT = 56.23 INCHES
WATER VOL = 19 GALS
WATER = 1.07 INCHES
TEMP = 63.4 DEG F

T 2:PNL
VOLUME = 1708 GALS
ULLAGE = 8342 GALS
90% ULLAGE = 7337 GALS
TC VOLUME = 1697 GALS
HEIGHT = 21.74 INCHES
WATER VOL = 13 GALS
WATER = 0.81 INCHES
TEMP = 68.3 DEG F

***** END *****

Note 96 inch tank Highlands Steel tank 10026
147 inches total -
Drop tube CUT TO 142