

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

JUL 6, 2023 2:04 PM

LEAK TEST REPORT

T 1:RNL
PROBE SERIAL NUM 281204

NO TEST DATA AVAILABLE

***** END *****

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

JUL 6, 2023 2:04 PM

LEAK TEST REPORT

T 2:PNL
PROBE SERIAL NUM 759411

NO TEST DATA AVAILABLE

***** END *****

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

JUL 6, 2023 2:04 PM

WPLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:
LAST TEST:
JUL 6, 2023 1:50PM PASS
NUMBER OF TESTS PASSED
PREV 24 HOURS : 114
SINCE MIDNIGHT : 59

0.20 GAL/HR RESULTS:
NO 0.20 DATA AVAILABLE
0.10 GAL/HR RESULTS:
NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:
LAST TEST:
JUL 6, 2023 2:01PM PASS
NUMBER OF TESTS PASSED
PREV 24 HOURS : 135
SINCE MIDNIGHT : 75

0.20 GAL/HR RESULTS:
NO 0.20 DATA AVAILABLE
0.10 GAL/HR RESULTS:
NO 0.10 DATA AVAILABLE