

CONOCO
104 E LINCOLNWAY
LA PORTE IN 46360

FEB 9, 2024 11:54 AM
CSLD TEST RESULTS
FEB 9, 2024 11:54 AM

T 1:RNL
PROBE SERIAL NUM 281204
0.2 GAL/HR TEST
PER: FEB 9, 2024 PASS

T 2:PNL
PROBE SERIAL NUM 759411
0.2 GAL/HR TEST
PER: FEB 9, 2024 PASS

***** END *****

CONOCO
104 E LINCOLNWAY
LA PORTE IN 46360

FEB 9, 2024 11:54 AM
WFLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:
LAST TEST:
FEB 9, 2024 11:29AM PASS
NUMBER OF TESTS PASSED
PREV 24 HOURS : 80
SINCE MIDNIGHT : 28

0.20 GAL/HR RESULTS:
NO 0.20 DATA AVAILABLE
0.10 GAL/HR RESULTS:
NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:
LAST TEST:
FEB 9, 2024 11:29AM PASS
NUMBER OF TESTS PASSED
PREV 24 HOURS : 90
SINCE MIDNIGHT : 32

0.20 GAL/HR RESULTS:
NO 0.20 DATA AVAILABLE
0.10 GAL/HR RESULTS:
NO 0.10 DATA AVAILABLE

***** END *****

CONOCO
104 E LINCOLNWAY
LA PORTE IN 46360

FEB 9, 2024 11:54 AM
LEAK TEST REPORT
T 1:RNL
PROBE SERIAL NUM 281204

NO TEST DATA AVAILABLE
***** END *****

CONOCO
104 E LINCOLNWAY
LA PORTE IN 46360

FEB 9, 2024 11:54 AM
LEAK TEST REPORT
T 2:PNL
PROBE SERIAL NUM 759411

NO TEST DATA AVAILABLE
***** END *****