

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

NOV 13, 2024 4:13 PM

CSLD TEST RESULTS

NOV 13, 2024 4:13 PM

T 1:RNL
PROBE SERIAL NUM 281204

0.2 GAL/HR TEST
PER: NOV 13, 2024 PASS

T 2:PNL
PROBE SERIAL NUM 759411

0.2 GAL/HR TEST
PER: NOV 13, 2024 PASS

***** END *****

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

NOV 13, 2024 4:14 PM

WPLLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:
NOV 13, 2024 4:00PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 73
SINCE MIDNIGHT : 44

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:
NOV 13, 2024 3:59PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 78
SINCE MIDNIGHT : 49

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE