

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

DEC 15, 2024 4:32 PM

CSLD TEST RESULTS

DEC 15, 2024 4:32 PM

T 1:RNL
PROBE SERIAL NUM 281204

0.2 GAL/HR TEST
PER: DEC 15, 2024 PASS

T 2:PNL
PROBE SERIAL NUM 759411

0.2 GAL/HR TEST
PER: DEC 15, 2024 PASS

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

DEC 15, 2024 4:32 PM

WPLLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:
DEC 15, 2024 4:18PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 69
SINCE MIDNIGHT : 53

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:

DEC 15, 2024 4:17PM PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 71

SINCE MIDNIGHT : 58

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

* * * * * END * * * * *

CONOCO

104 E LINCONWAY

LAPORTE IN 46360

DEC 15, 2024 4:32 PM

LEAK TEST REPORT

T 1:RNL

PROBE SERIAL NUM 281204

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CONOCO

104 E LINCONWAY

LAPORTE IN 46360

DEC 15, 2024 4:32 PM

LEAK TEST REPORT

T 2:PNL

PROBE SERIAL NUM 759411

NO TEST DATA AVAILABLE

* * * * * END * * * * *