

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

MAY 10, 2024 2:10 PM

CSLD TEST RESULTS

MAY 10, 2024 2:10 PM

T 1:RNL
PROBE SERIAL NUM 281204

0.2 GAL/HR TEST
PER: MAY 10, 2024 PASS

***** END *****

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

MAY 10, 2024 2:10 PM

WPLLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:
MAY 10, 2024 1:45PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 80
SINCE MIDNIGHT : 47

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:
MAY 10, 2024 1:45PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 82
SINCE MIDNIGHT : 48

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

***** END *****