

 EZY CHEK SYSTEMS LEAK DETECTOR TEST REVISION 8/21/2019				DATE AND TIME		8/15/22 1100-1400		
				WEATHER		80 Sunny		
				COLLECT/INVOICE		COLLECT		
				CLIENT EMAIL		-		
				Testing Company Information				
Test Location Information				Certifications		Name		Midwest Tank Testing
PC # and WO #				Estabrooks: 25-8686		Address		316 W. Indiana Ave.
Name and FID #		FID # 2871		ICC: 10224553		City/State/Zip		Chesterton, IN 46304
Address		104 E Lincolnway		Indiana: UC110601		Phone		800-975-1436
City/State/Zip		LaPorte IN 46350				Technician Information		
Contact				Illinois: 002401		Name		Seth Lynn
Phone						Email		support@midwesttanktesting.com
TYPE OF LEAK DETECTOR - (LD) or (ELD)								
PUMP #	PRODUCT			MODEL		SERIAL # (If Legible)		
1	Regular			ELD		N/A		
2	Premium			ELD		N/A		
3								
4								
5								
6								
7								
8								
LEAK DETECTOR TEST								
PUMP #	Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Cycles	Results	
1	Regular	-	-	-	189ml	-	Pass	
2	Premium	-	-	-	189ml	-	Pass	
3								
4								
5								
6								
7								
8								
COMMENTS/RECOMMENDATIONS: ALL ELD'S function properly, cycled two times and caused gross line fail and shut down.								