

 Midwest Tank Testing AN ENVIRONMENTAL COMPLIANCE COMPANY 316 W. Indiana Ave. Chesterton, IN 46304		HYDROSTATIC SPILL BUCKET		DATE AND TIME		8/15/22 1100-1400		
		(HSB) INTEGRITY TEST		WEATHER		80 Sunny		
		DATA SHEET		COLLECT/INVOICE		COLLECT		
				CLIENT E-MAIL				
				Testing Company Information				
Test Location Information			Certifications		Name		Midwest Tank Testing	
PC # and WO #			Estabrooks: 25-8686		Address		316 W. Indiana Ave.	
Name and FID #		FID # 2871	ICC: 10224553		City/State/Zip		Chesterton, IN 46304	
Address		104 E Lincolnway	Indiana: UC110601		Phone		800-975-1436	
City/State/Zip		La Porte IN 46350	Technician Information					
Contact			Illinois: 002401		Name		Seth Lynn	
Phone					Email		support@midwesttanktesting.com	
HYDROSTATIC SPILL BUCKET (HSB) INTEGRITY TEST								
This procedure is to test the leak integrity of single and double walled spill buckets. See PEI/RP1200 Section 6.2 for hydrostatic test method.								
Tank #	1	2						
Product Stored	Regular	Premium						
Manufacturer								
Construction (Single Wall/Double Wall)	Single	Single						
Test Type (Single Wall/Double Wall)	HYDROST. SINGLE WALL	HYDROST. SINGLE WALL						
Spill Bucket Type (Product/Vapor)	Product	Product						
Liquid and Debris Removed From Spill Bucket? (All liquids & debris must be disposed of properly) (Yes/No)	Yes	Yes						
Visual Inspection (No cracks, loose parts or separation of bucket from the fill pipe) If fail, omit hydrostatic test. (Pass/Fail)	Pass	Pass						
Tank Riser Cap Included In Test? (Yes, No, N/A)	Yes	Yes						
Drain Valve Included In Test? (Yes, No, N/A)	Yes	Yes						
Starting Water Level (inches)	12	12						
Test Start Time	12:00 PM	12:00 PM						
Ending Water Level (inches)	12	12						
Test End Time	1:00 PM	1:00 PM						
Test Period (minutes)	60	60						
Water Level Change (inches)	0	0						
Pass/Fail Criteria: Must pass visual inspection. Hydrostatic: Water level drop of less than 1/8"								
Test Results (Pass/Fail)	Pass	Pass						
Comments:								