

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

AUG 8, 2024 4:28 PM

WPLLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:
AUG 8, 2024 4:21PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 97
SINCE MIDNIGHT : 68

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:
AUG 8, 2024 4:27PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 107
SINCE MIDNIGHT : 76

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

AUG 8. 2024 4:28 PM

WPLLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:
AUG 8.2024 4:21PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 97
SINCE MIDNIGHT : 68

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:
AUG 8.2024 4:27PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 107
SINCE MIDNIGHT : 76

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

AUG 8, 2024 4:28 PM

CSLD TEST RESULTS

- - - - -
AUG 8, 2024 4:28 PM

T 1:RNL
PROBE SERIAL NUM 281204

0.2 GAL/HR TEST
PER: AUG 8, 2024 PASS

T 2:PNL
PROBE SERIAL NUM 759411

0.2 GAL/HR TEST
PER: AUG 8, 2024 PASS

* * * * * END * * * * *