

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

MAR 7, 2024 2:47 PM

CELD TEST RESULTS

MAR 7, 2024 2:47 PM

T 1:RNL
PROBE SERIAL NUM 281204

0.2 GAL/HR TEST
PER: MAR 7, 2024 PASS

T 2:PNL
PROBE SERIAL NUM 759411

0.2 GAL/HR TEST
PER: MAR 7, 2024 PASS

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

MAR 7, 2024 2:47 PM

WPLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:
MAR 7, 2024 2:47PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 79
SINCE MIDNIGHT : 40

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:
MAR 7, 2024 2:46PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 80
SINCE MIDNIGHT : 38

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

MAR 7, 2024 2:47 PM

LEAK TEST REPORT

T 1:RNL
PROBE SERIAL NUM 281204

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

MAR 7, 2024 2:47 PM

LEAK TEST REPORT

T 2:PNL
PROBE SERIAL NUM 759411

NO TEST DATA AVAILABLE

* * * * * END * * * * *