

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

JUL 13, 2024 3:37 PM

CSLD TEST RESULTS

JUL 13, 2024 3:37 PM

T 1:RNL
PROBE SERIAL NUM 281204

0.2 GAL/HR TEST
PER: JUL 13, 2024 PASS

***** END *****

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

JUL 13, 2024 3:37 PM

WPLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:
JUL 13, 2024 3:37PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 96
SINCE MIDNIGHT : 60

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:
JUL 13, 2024 3:34PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 99
SINCE MIDNIGHT : 63

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE