

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

SEP 21, 2024 2:18 PM

CSLD TEST RESULTS

SEP 21, 2024 2:18 PM

T 1:RNL
PROBE SERIAL NUM 281204

0.2 GAL/HR TEST
PER: SEP 21, 2024 PASS

T 2:PNL
PROBE SERIAL NUM 759411

0.2 GAL/HR TEST
PER: SEP 21, 2024 PASS

***** END *****

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

SEP 21, 2024 2:18 PM

WPLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:
SEP 21, 2024 2:11PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 85
SINCE MIDNIGHT : 45

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:
SEP 21, 2024 2:10PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 93
SINCE MIDNIGHT : 49

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

SEP 21, 2024 2:18 PM

LEAK TEST REPORT

T 1:RNL
PROBE SERIAL NUM 281204

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

SEP 21, 2024 2:18 PM

LEAK TEST REPORT

T 2:PNL
PROBE SERIAL NUM 759411

NO TEST DATA AVAILABLE

* * * * * END * * * * *