

|                                       |                                          |
|---------------------------------------|------------------------------------------|
| UST Facility I.D. (FID) # <b>2871</b> | Contact Number                           |
| Facility Name <b>CONOCO</b>           | Contact email                            |
| Address <b>104 Lincolnway E 46350</b> | Date of Inspection <b>06-13-2025</b>     |
| Operator on Duty Name                 | Name of the Person Conducting Inspection |

|                                                                   |                                                                |                                                                                |                                                    |
|-------------------------------------------------------------------|----------------------------------------------------------------|--------------------------------------------------------------------------------|----------------------------------------------------|
| <b>Operator Training</b>                                          |                                                                | <b>Operator Notified</b>                                                       |                                                    |
| Operator Training current                                         | <input type="radio"/> Yes <input type="radio"/> No             | <input type="radio"/> Yes <input type="radio"/> No                             |                                                    |
| <b>Registration/Notification Form</b>                             |                                                                | <b>Operator Notified</b>                                                       |                                                    |
| Is Registration current with correct owner, operator etc.         | <input type="radio"/> Yes <input type="radio"/> No             | <input type="radio"/> Yes <input type="radio"/> No                             |                                                    |
| <b>Release Detection</b>                                          |                                                                | <b>Operator Notified</b>                                                       |                                                    |
| Release Detection Method                                          | <input checked="" type="radio"/> ATG <input type="radio"/> CIM | <input type="radio"/> SIR <input type="radio"/> IC <input type="radio"/> Other |                                                    |
| Make and Model <b>VRTLS-351</b>                                   |                                                                | <b>Operator Notified</b>                                                       | <input type="radio"/> Yes <input type="radio"/> No |
| Does it have paper?                                               | <input checked="" type="radio"/> Yes <input type="radio"/> No  | <b>Operator Notified</b>                                                       | <input type="radio"/> Yes <input type="radio"/> No |
| Is it in Alarm mode?                                              | <input checked="" type="radio"/> Yes <input type="radio"/> No  | <b>Operator Notified</b>                                                       | <input type="radio"/> Yes <input type="radio"/> No |
| Interstitial Monitoring Sensor Status Normal                      | <input checked="" type="radio"/> Yes <input type="radio"/> No  | <b>Operator Notified</b>                                                       | <input type="radio"/> Yes <input type="radio"/> No |
| Necessary Monthly Printout Taken                                  | <input checked="" type="radio"/> Yes <input type="radio"/> No  | <b>Operator Notified</b>                                                       | <input type="radio"/> Yes <input type="radio"/> No |
| <b>Spill Buckets</b>                                              |                                                                | <b>Operator Notified</b>                                                       |                                                    |
| Are Spill Buckets Clean and free from water, debris, product etc? | <input type="radio"/> Yes <input checked="" type="radio"/> No  | <input checked="" type="radio"/> Yes <input type="radio"/> No                  |                                                    |
| Are the Spill Bucket in good condition and free of damage/cracks  | <input checked="" type="radio"/> Yes <input type="radio"/> No  | <input type="radio"/> Yes <input type="radio"/> No                             |                                                    |
| <b>Fill Ports</b>                                                 |                                                                | <b>Operator Notified</b>                                                       |                                                    |
| Is Fill pipe cap tight and fill pipe free from any obstruction?   | <input type="radio"/> Yes <input type="radio"/> No             | <input type="radio"/> Yes <input type="radio"/> No                             |                                                    |
| <b>Piping/STP Sumps</b>                                           |                                                                | <b>Operator Notified</b>                                                       |                                                    |
| Are Sumps Clean and free from water, debris, product etc?         | <input type="radio"/> Yes <input checked="" type="radio"/> No  | <input checked="" type="radio"/> Yes <input type="radio"/> No                  |                                                    |
| <b>Under Dispenser Containments (UDC)</b>                         |                                                                | <b>Operator Notified</b>                                                       |                                                    |
| Are UDCs clean and free from water, debris, product etc?          | <input type="radio"/> Yes <input checked="" type="radio"/> No  | <input checked="" type="radio"/> Yes <input type="radio"/> No                  |                                                    |

**NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.**

Operator on Duty Name  
317-645-0215

tanksdata@gmail.com

Signature  
*[Signature]*

Date **06-13-2025**  
www.tanksdata.com