

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

APR 21, 2025 4:57 PM

LEAK TEST REPORT

T 1:RNL
PROBE SERIAL NUM 281204

NO TEST DATA AVAILABLE

***** END *****

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

APR 21, 2025 4:57 PM

CSLD TEST RESULTS

APR 21, 2025 4:57 PM

T 1:RNL
PROBE SERIAL NUM 281204

0.2 GAL/HR TEST
PER: APR 21, 2025 PASS

T 2:PNL
PROBE SERIAL NUM 759411

0.2 GAL/HR TEST
PER: APR 21, 2025 PASS

***** END *****

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

APR 21, 2025 4:57 PM

LEAK TEST REPORT

T 2:PNL
PROBE SERIAL NUM 759411

NO TEST DATA AVAILABLE

***** END *****

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

APR 21, 2025 4:57 PM

WPLLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:
APR 21, 2025 4:37PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 72
SINCE MIDNIGHT : 44

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:
APR 21, 2025 4:56PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 85
SINCE MIDNIGHT : 55

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

***** END *****