

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

FEB 16, 2025 5:41 PM

CSLD TEST RESULTS

- - - - -
FEB 16, 2025 5:41 PM

T 1:RNL

PROBE SERIAL NUM 281204

0.2 GAL/HR TEST

PER: FEB 16, 2025 PASS

T 2:PNL

PROBE SERIAL NUM 759411

0.2 GAL/HR TEST

PER: FEB 16, 2025 PASS

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

FEB 16, 2025 5:41 PM

WPLLD LINE LEAK

TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:

FEB 16, 2025 5:38PM PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 81

SINCE MIDNIGHT : 56

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:

FEB 16, 2025 5:37PM PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 90

SINCE MIDNIGHT : 64

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

* * * * * END * * * * *