

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) # 2871

Contact Number

Facility Name 60N0C0

Contact email

Address 104 Winkelman E

Date of Inspection 03/7/25

Operator on Duty Name LA-ROCK IN-46350

Name of the Person Conducting Inspection ANXIT

Operator Training current

Operator Training

☐ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Registration/Notification Form

Is Registration current with correct owner, operator etc.

☐ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Release Detection

Release Detection Method

☒ ATG ☐ TIM ☐ SIR ☐ IC ☐ Other

Make and Model

VR-25-350

Does it have paper?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Necessary Monthly Printout Taken

☐ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Spill Buckets

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Fill Ports

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Piping/STP Sumps

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Under Dispenser Containments (UDC)

Are UDCs clean and free from water, debris, product etc?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com