

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

MAR 7, 2025 4:04 PM

CSLD TEST RESULTS

MAR 7, 2025 4:04 PM

T 1:RNL
PROBE SERIAL NUM 281204

0.2 GAL/HR TEST
PER: MAR 7, 2025 PASS

T 2:PNL
PROBE SERIAL NUM 759411

0.2 GAL/HR TEST
PER: MAR 7, 2025 PASS

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

MAR 7, 2025 4:04 PM

WPLLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:
MAR 7, 2025 4:02PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 82
SINCE MIDNIGHT : 59

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:
MAR 7, 2025 4:02PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 87
SINCE MIDNIGHT : 64

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

* * * * * END * * * * *

LEAK TEST STATUS:
TEST NOT IN PROGRESS