

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

JAN 16, 2025 6:15 PM

CSLD TEST RESULTS

JAN 16, 2025 6:15 PM

T 1:RNL

PROBE SERIAL NUM 281204

0.2 GAL/HR TEST

PER: JAN 16, 2025 PASS

T 2:PNL

PROBE SERIAL NUM 759411

0.2 GAL/HR TEST

PER: JAN 16, 2025 PASS

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

JAN 16, 2025 6:15 PM

WPLLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:

JAN 16, 2025 6:11PM PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 95

SINCE MIDNIGHT : 77

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:

JAN 16.2025 6:13PM PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 104

SINCE MIDNIGHT : 85

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

* * * * * END * * * * *

CONOCO

104 E LINCONWAY

LAPORTE IN 46360

JAN 16. 2025 6:15 PM

LEAK TEST REPORT

T 1:RNL

PROBE SERIAL NUM 281204

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CONOCO

104 E LINCONWAY

LAPORTE IN 46360

JAN 16. 2025 6:15 PM

LEAK TEST REPORT

T 2:PNL

PROBE SERIAL NUM 759411

NO TEST DATA AVAILABLE

* * * * * END * * * * *