



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 2871
Address	104 Lincolnway E
City	La Porte, IN, 46350
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Red Jacket ELLD		
Prem	Red Jacket ELLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	34	28	1000+ ml	189ml	2 cycles	Pass v
2	Premium	35	25	1000+ ml	189ml	2 cycles	Pass v
3					189ml		. v
4					189ml		. v
5					189ml		. v
6					189ml		. v
7					189ml		. v
8					189ml		. v

Comment:

Technician Signature :

