



5296 Breakers Way, Carmel, IN 46033

Date 11/27/24

PRODUCT LINE TEST

Test Location Information

Name	FID 2871
Address	104 Lincolnway E
City	La Porte, IN, 46350
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
12:40p	90	0	0.0037	0	0
12:55p	86	-4	0.0037	.0148	.0592
1:10pm	84	-2	0.0037	.0074	.0296
1:25pm	82	-2	0.0037	.0074	.0296
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
1:50pm	88	0	0.0037	0	0
2:05pm	87	-1	0.0037	.0037	.0148
2:20pm	87	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 11/27/24

PRODUCT LINE TEST

Test Location Information

Name	FID 2871
Address	104 Lincolnway E
City	La Porte, IN, 46350
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3		.
4		.
5		.
6		.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 