

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

MAY 11, 2025 8:07 PM

LEAK TEST REPORT

T 1:RNL
PROBE SERIAL NUM 281204

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

MAY 11, 2025 8:07 PM

LEAK TEST REPORT

T 2:PNL
PROBE SERIAL NUM 759411

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

MAY 11, 2025 8:07 PM

WPLLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:

MAY 11, 2025 8:07PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 86
SINCE MIDNIGHT : 78

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:

MAY 11, 2025 8:06PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 89
SINCE MIDNIGHT : 83

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

* * * * * END * * * * *