

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

SEP 14, 2025 5

CSLD TEST RESULT

SEP 14, 2025 5

T 1:RNL

PROBE SERIAL NUM

0.2 GAL/HR TEST

PER: SEP 14, 202

T 2:PNL

PROBE SERIAL NUM

0.2 GAL/HR TEST

PER: SEP 14, 202

* * * * * END * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

SEP 14, 2025 5:52

WPLLD LINE LEAK

TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:

SEP 14, 2025 5:47PM PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 86

SINCE MIDNIGHT : 67

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:

SEP 14, 2025 5:46PM PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 93

SINCE MIDNIGHT : 75

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

END * * * * *