

AUG 11, 2025 5:37 PM
CSLD TEST RESULTS
- - - - -
AUG 11, 2025 5:37 PM

T 1:RNL
PROBE SERIAL NUM 281204
0.2 GAL/HR TEST
PER: AUG 11, 2025 PASS

T 2:PNL
PROBE SERIAL NUM 759411
0.2 GAL/HR TEST
PER: AUG 11, 2025 PASS

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

AUG 11, 2025 5:37 PM
CSLD TEST RESULTS
- - - - -
AUG 11, 2025 5:37 PM

T 1:RNL
PROBE SERIAL NUM 281204
0.2 GAL/HR TEST
PER: AUG 11, 2025 PASS

T 2:PNL
PROBE SERIAL NUM 759411
0.2 GAL/HR TEST
PER: AUG 11, 2025 PASS

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

AUG 11, 2025 5:37 PM
WPLLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:
LAST TEST:
AUG 11, 2025 5:36PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 78
SINCE MIDNIGHT : 54

0.20 GAL/HR RESULTS:
NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:
NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:
LAST TEST:
AUG 11, 2025 5:35PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 80
SINCE MIDNIGHT : 56

0.20 GAL/HR RESULTS:
NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:
NO 0.10 DATA AVAILABLE

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360
AUG 11. 2025 5:37 PM
WPLLD LINE LEAK
TEST RESULTS
W 1:UNL
3.0 GAL/HR RESULTS:
LAST TEST:
AUG 11.2025 5:36PM PASS
NUMBER OF TESTS PASSED : 78
PREV 24 HOURS : 54
SINCE MIDNIGHT :
0.20 GAL/HR RESULTS:
NO 0.20 DATA AVAILABLE
0.10 GAL/HR RESULTS:
NO 0.10 DATA AVAILABLE

W 2:PRM
3.0 GAL/HR RESULTS:
LAST TEST:
AUG 11.2025 5:35PM PASS
NUMBER OF TESTS PASSED : 80
PREV 24 HOURS : 56
SINCE MIDNIGHT :
0.20 GAL/HR RESULTS:
NO 0.20 DATA AVAILABLE
0.10 GAL/HR RESULTS:
NO 0.10 DATA AVAILABLE

***** END *****

CONOCO
104 E LINCONWAY
LAPORTE IN 46360
AUG 11. 2025 5:38 PM
WPLLD LINE LEAK
TEST RESULTS
W 1:UNL
3.0 GAL/HR RESULTS:
LAST TEST:
AUG 11.2025 5:36PM PASS
NUMBER OF TESTS PASSED : 78
PREV 24 HOURS : 54
SINCE MIDNIGHT :
0.20 GAL/HR RESULTS:
NO 0.20 DATA AVAILABLE
0.10 GAL/HR RESULTS:
NO 0.10 DATA AVAILABLE

W 2:PRM
3.0 GAL/HR RESULTS:
LAST TEST:
AUG 11.2025 5:35PM PASS
NUMBER OF TESTS PASSED : 80
PREV 24 HOURS : 56
SINCE MIDNIGHT :
0.20 GAL/HR RESULTS:
NO 0.20 DATA AVAILABLE
0.10 GAL/HR RESULTS:
NO 0.10 DATA AVAILABLE
***** END *****