

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

OCT 10, 2025 5:05 PM

CSLD TEST RESULTS

OCT 10, 2025 5:05 PM

T 1:RNL
PROBE SERIAL NUM 281204

0.2 GAL/HR TEST
PER: OCT 10, 2025 PASS

T 2:PML
PROBE SERIAL NUM 759411

0.2 GAL/HR TEST
PER: OCT 10, 2025 PASS

* * * * * END * * * * *

CONOCO
104 E LINCONWAY
LAPORTE IN 46360

OCT 10, 2025 5:05 PM

WPLLD LINE LEAK
TEST RESULTS

W 1:UNL

3.0 GAL/HR RESULTS:

LAST TEST:
OCT 10, 2025 4:40PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 91

SINCE MIDNIGHT : 70

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

W 2:PRM

3.0 GAL/HR RESULTS:

LAST TEST:
OCT 10, 2025 4:39PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 105

SINCE MIDNIGHT : 83

0.20 GAL/HR RESULTS:

NO 0.20 DATA AVAILABLE

0.10 GAL/HR RESULTS:

NO 0.10 DATA AVAILABLE

* * * * * END * * * * *