

CITGO
502 HWY 20
M CITY IN 46360

APR 30, 2023 3:38 PM

LEAK TEST REPORT

T 1:PREMIUM
PROBE SERIAL NUM 754662

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CITGO
502 HWY 20
M CITY IN 46360

APR 30, 2023 3:38 PM

CSLD TEST RESULTS

APR 30, 2023 3:38 PM

T 1:PREMIUM
PROBE SERIAL NUM 754662

0.2 GAL/HR TEST
PER: APR 29, 2023 PASS

T 3:RNL SOUTH
PROBE SERIAL NUM 704164

0.2 GAL/HR TEST
PER: APR 30, 2023 FAIL

T 4:DIESEL
PROBE SERIAL NUM 570008

0.2 GAL/HR TEST
PER: APR 30, 2023 PASS

* * * * * END * * * * *