

CITGO
502 HWY 20
M CITY IN 46360

MAY 17, 2023 11:08 AM

CSLD TEST RESULTS

MAY 17, 2023 11:08 AM

T 2:RNL NORTH
PROBE SERIAL NUM 754662

0.2 GAL/HR TEST
PER: MAY 17, 2023 PASS

T 3:RNL SOUTH
PROBE SERIAL NUM 704164

0.2 GAL/HR TEST
PER: MAY 17, 2023 FAIL

* * * * * END * * * * *

CITGO
502 HWY 20
M CITY IN 46360

MAY 17, 2023 11:08 AM

LEAK TEST REPORT

T 2:RNL NORTH
PROBE SERIAL NUM 754662

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CITGO
502 HWY 20
M CITY IN 46360

MAY 17, 2023 11:08 AM

LEAK TEST REPORT

T 3:RNL SOUTH
PROBE SERIAL NUM 704164

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CITGO
502 HWY 20
M CITY IN 46360

MAY 17, 2023 11:08 AM

LEAK TEST REPORT

T 4:DIESEL
PROBE SERIAL NUM 570008

NO TEST DATA AVAILABLE

* * * * * END * * * * *